

ADDENDUM NO. 2

TO: ALL BIDDERS OF RECORD

PROJECT: Amelia Island Site Development

FWP PROJECT #: 7133736

DATE: 09/24/2014

FROM: Jason Senn, Montana FWP Project Manager



Acknowledge receipt of this addendum by inserting its number and date in the Proposal Form and on the Bid Envelope. Failure to do so may subject bidder to disqualification.

This Addendum forms a part of the Contract Documents. Clarification and/or modifications area as follows:

Plan Sheet 8 of 9 – Barrier Post and Cable Detail;

- Re-purposed wood post w/ pre-drilled holes will be provided to the contractor by MT FWP. The contractor will be responsible to install the wood posts and provided and install the barrier cable.

General – Site Access;

- Contractor will be responsible for providing a temporary bridging structure, rated for the heaviest piece of equipment they will use, to span across the existing bridge over the irrigation canal on Pumphouse Road. Proposed temporary bridging structure must be certified by a professional engineer. Contractor must provide certification to owner prior to installation of proposed structure. Cost of this structure shall be included within the existing bid items and will not be paid for separately.
- Owner is open to alternative means of delivering equipment and materials to site, such as barging or air transport. Contractor will be responsible for obtaining any permits required for alternative means of delivering equipment and materials.